

875—73.25(89A) Sprinkler retrofits and shunt trip breakers. When a sprinkler is added to a hoistway or machine room, the conveyance shall comply with the following:

73.25(1) The installation shall comply with the applicable version of ASME A17.1 Rule 2.8.3.3.

73.25(2) The elevator controls shall be arranged to comply with the phase I fire recall provisions of the applicable version of ASME A17.1 Rule 2.27.3.

73.25(3) The applicable version of ASME A17.1 shall be determined by reference to rule 875—72.1(89A). For purposes of this rule, the relevant subrule of 875—72.1(89A) shall be based on the date the sprinkler is installed instead of the date the conveyance was installed.